



MADHYA PRADESH CRICKET ASSOCIATION

Holkar Stadium, Race Course Road, Indore | Tel : (0731) 2543602 | Email : secretary@mpcaonline.com

NOTICE INVITING OFFERS FOR SUPPLY & OPERATIONS OF DG SET ON RENTAL BASIS, TEMPORARY LIGHT, SOUND SYSTEM (PA) FOR INTERNATIONAL CRICKET MATCH

(by advertisement in newspaper and display on website of MPCA)

1. MPCA invites proposal and commercial offer from experienced service providers for supply and installation on rental basis, commissioning and operation of DG set of specific manufacturers and output, temporary light (illumination) & sound (pa) system for the international cricket match at Holkar Stadium.
2. Match date : 4th October 2022
3. Setup to be ready for testing : By 9.00 pm on 2nd October 2022.
4. Setup should be upto satisfaction of the local police department and electrical safety department.
5. Scope of work : As per the annexure
6. It is specifically intimated to all concerned that the responsibility of insurance / PPF / PF / ESI for the workmen shall be of the concerned agency. Necessary documentation shall be furnished to MPCA prior to the commencement of work. IN ANY CASE, MPCA SHALL NOT BE RESPONSIBLE FOR ANY COMPLIANCES IN THIS REGARD AND NO LIABILITY LIES ON MPCA. IN CASE IF REQUIRED, MPCA RESERVES ALL RIGHTS TO RECOVER FROM US ANY LIABILITY IMPOSED BY ANY STATUTORY BODY FOR THE DEFAULT OF US IN SUCH AREAS.
7. EMD : Rs. 1,00,000/- by way of DD in favour of M P Cricket Association payable at Indore.
8. EMD of selected agency shall be converted into interest free Security deposit.
9. MPCA shall demand conflict of declaration and any other relevant declaration from the shortlisted agency before awarding contract.
10. Last dated for submission of offer : **22.9.2022 by 12.00 noon at MPCA office** (Holkar Stadium, Race Course rd., Indore)
11. Offer should be placed in a seal envelope addressed to the Hon. Secretary, MPCA. The envelope should have the details of the offerer.
12. Envelope should contain following minimum documents –
 - 12.1 A covering letter and profile of the agency.
 - 12.2 Self attested copy of valid license / registration for running a business in Indore / state of MP.
 - 12.3 Registration with the GST department if available.
 - 12.4 Brief note about experience of similar service for events.
 - 12.5 Plan to complete scope of work within the defined period.
 - 12.6 Commercial quote

Issued by Hon. Secretary, MPCA

Date : 19th September 2022

SCOPE OF WORK SUPPLY & OPERATIONS OF DG SET ON RENTAL BASIS, TEMPORARY LIGHT, SOUND SYSTEM (PA) FOR INTERNATIONAL CRICKET MATCH (INCLUDING BUT NOT LIMITED TO)

1. Supply, installation on rental basis, commissioning and operation of the dg set of following manufacturers and rendering specific output

- | | | |
|-----|---|---------------|
| i. | 160/200 KVA with AMF / cable (Kirloskar / Cummins / Mahendra / Caterpillar) | Upto 5 units |
| ii. | 250/320 KVA with AMF / cable (Kirloskar / Cummins / Mahendra / Caterpillar) | Upto 5 units |
| i. | 125 KVA with AMF / cable (Kirloskar / Cummins / Mahendra / Caterpillar) | Upto 10 units |

DG set should not be more than 3 years old and should be able to generate 75% to 80% power in terms of capacity.

The commercial offer should be on basis of rent per 24 hours + operator (for shift of 4 hours, 8 hours, 12 hours, and 16 hours), and diesel consumption per hour according to DG set capacity. Any liaisoning charges should be mentioned separately.

2. Supply, commissioning and operation of temporary lights of specific output at various locations inside stadium premise (approx. length 1500 rft) and outside stadium premise (approx. 1000 rft).

- i. Halogen fitting : 500 w- 1000 w: approx. 125 nos
OR
LED fitting equivalent to above output
- ii. LED floodlight : 400 w: approx. 200 nos
- iii. Cable, power-plugs and other accessories for above connections

3. General PA system, including equipment, wiring and installation of amplifiers of various capacities as per the on-site requirement (indoor and out-door utilities) of brands like JBL / Bose / Philips / RCF / EAW or equivalent

- | | | |
|------|---|---|
| i. | Inside stadium structure (GL + upper tiers) | approx. 40 horns + 2 mike with input from police control room located at II tier of north pavilion) |
| ii. | Inside stadium (for TV broadcast, 8 locations) | approx. 8 speakers of 1000 w + 2 mikes |
| iii. | Stadium entry gates (1 mike + 1 horn + 1 appropriate ampl.) | approx. 9 – 10 sets |
| iv. | Trolley speaker (min. 60 w) + mike | approx. 2 – 3 sets |

Kindly note :

- a. The requirement would be on match day and 2 days before.
- b. Each DG set will have min. 2 technically qualified operators. The responsibility of procuring diesel and necessary arrangement shall rest on the agency.
- c. Electric light arrangement including wiring and power source identification – connection. Wiring shall be done as per IS codes (if applicable) using proper connection devices, good quality and un-tampered wire/cable of appropriate capacity and suitable earthing wherever necessary. The responsibility of any technical – electrical snag or short-circuit etc. shall be solely responsibility of the service provider.
- d. The wiring should be preferably under-ground using conduits, else over-head with all protections. In case if any wire / cable / connection is near any public approach / pathway / assembly area etc., the same should be properly arranged and signage be displayed.
- e. Provide, if necessary according to the electrical consultant of MPCA, certification from the any statutory agency about satisfactory installation of the set up. The responsibility of obtaining appropriate statutory permissions / certifications etc. shall be that of the service provider. Such approval / certification is required to be provided atleast 2 days before the match.